



No. 2014-022235-02

안전인증서

Certificate of Safety

GASTRON CO.,LTD.

18-8, Dogeumdanji 1-gil, Sangrok-gu, Ansan-si, Gyeonggi-do, Korea

The following product manufactured by the above company has been authorized for the use of safety certification mark as the product has satisfied the safety and health requirements under Article 34 of OCCUPATIONAL SAFETY AND HEALTH ACT and paragraph 4 of Article 58-4 of ENFORCEMENT ORDINANCE OF the same ACT.

Electrical Equipment

GAS DETECTOR

Model (Marking) / Certificate No.

GTD-2000Tx (Ex d IIC T6,T4) / 14-KB2BO-0369

Applied standards

Announcement No. 2013-54 of Ministry of Employment and Labor

Conditions of Certification

- 1. Manufacturing location(s):** This certificate is only valid for the specified products produced at '18-8, Dogeumdanji 1-gil, Sangrok-gu, Ansan-si, Gyeonggi-do, Korea'.
- 2. Description of equipment**
 - Rating: 24 Vdc, 150 mA
 - Ambient Temperature: $-40\text{ }^{\circ}\text{C} \leq T_a \leq +60\text{ }^{\circ}\text{C}$ (for T6), $-40\text{ }^{\circ}\text{C} \leq T_a \leq +80\text{ }^{\circ}\text{C}$ (for T4)
- 3. Scope of certification :** This certificate is only valid for the models as above.
- 4. Special conditions for safe use:** None
- 5. Details of certificate changes:** None
- 6. Details of the others:** Manufacturer shall take the responsibility including maintaining quality requirements for the certified products, receiving factory surveillance and informing any changes to the certified products.

Date of Issue : 2014-7-9

한국산업기술시험원장
KOREA TESTING LABORATORY

